



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**CRIAPBMa. Circuit Breaker.**

NI / I / 2 / ABCD / T5 Ta = 65°C  
a = Amps - 1, 2, 3, 5, 7.5 and 10

**CRIAPBMa. Circuit Breaker.**

NI / I / 2 / ABCD / T5 Ta = 55°C  
a = Amps - 15 and 20

**Special Conditions of Use:**

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including access only by use of a tool. In Class I, Division 2 installations, the subject equipment shall be the tool-secured enclosure shall be capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70).
2. Verify all accessible conductive parts are bonded to the protective earth terminal, with a resistance of less than 0.1 ohms, during installation.
3. The connection between the protective earth terminal and the accessible conductive parts shall be capable of carrying 25 Amps d.c or a.c. rms for one minute.

### Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, D hazardous (classified) locations.

### FM Approved for:

CRI Circuit Protection Products LLC  
Houston, TX United States



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	2005

Original Project ID: 0003054896

Approval Granted: October 1, 2015

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J.E. Marquedant  
Manager of Electrical Systems

1 October 2015

Date